

# Need for a Holistic Approach to Assessing Sustainable, Green, and Healthy Buildings

Nishchaya Kumar Mishra and Sameer Patel\*



Cite This: *Environ. Health* 2025, 3, 218–226



Read Online


ACCESS |

Metrics & More

Article Recommendations

**ABSTRACT:** With the rising global population, economic development, and urbanization, building stock is bound to grow, warranting measures for optimizing their embodied and operational energy and resource consumption. Further, a building's indoor environment quality significantly affects occupants' health, productivity, and well-being since people spend almost 90% of their time indoors. Buildings safeguard occupant's well-being by shielding them from the outdoor air pollution and increasing climate extremes. However, buildings can also lead to acute and chronic exposure to pollutants trapped inside. The recent pandemic has demonstrated that indoor environments can prevent and promote airborne disease transmission depending on buildings' design and operation. The current segregated rating systems and regulations to gauge buildings' sustainability, health and safety, and energy efficiency have led to a fragmented approach hampering sustainable and healthy buildings' design, construction, and operations. This work discusses the environmental sustainability of buildings, their impacts on occupants' health and productivity, and if and how the existing global policies and frameworks regulate and promote the same. Developing a holistic and comprehensive framework is critical to ensure buildings' sustainability, occupants' health, and energy efficiency.

**KEYWORDS:** sustainable and healthy buildings, building codes, energy-exposure trade-offs, health and well-being, green building rating systems



## 1. INTRODUCTION

As more of the world transitions from being developing to developed, it is increasingly important for researchers and policymakers to focus on buildings, which can either protect or harm public health and the environment, depending on their design and operation. Built environments comprising buildings are critical for societal and economic development<sup>1</sup> and, therefore, often used as a proxy for a nation's growth. While comprehensive regulations and codes govern the planning and construction of buildings, minimal attention has been given to indoor air quality and the risk of infectious diseases and their interplay with building design and operation. This oversight has grave implications for public health, considering people now spend most of their time in indoor spaces,<sup>2,3</sup> potentially leading to indoor exposure to airborne pollutants and pathogens dominating that occurs outdoors. Apart from occupants' health, buildings severely impact the environment. Building construction is highly resource intensive, and embodied and operational energy accounts for a significant, if not the major, fraction of global energy consumption and, therefore, contributes to climate change.<sup>4,5</sup>

Building performance in terms of environmental impacts, energy efficiency, and occupants' thermal comfort has been guiding building design, construction, and operation. However, various stakeholders are yet to recognize or acknowledge that

exposure to airborne pollutants and pathogens must be accounted for to ensure occupants' well-being. Although the sources and impacts of indoor air pollutants (IAPs) or household air pollutants (HAPs) have been researched intensively, the practical implications of such studies on building design and operation are limited.<sup>6</sup> The outbreak of the COVID-19 pandemic brought the focus to the risk of infectious disease transmission in indoor environments. Multiple superspreading events observed and studied during the pandemic demonstrated a much higher risk of spreading airborne pathogens indoors than outdoors. Indoor environments can lead to acute and chronic exposure to pathogens as airborne pathogens get trapped in a finite volume. Studies on transport and the fate of airborne pathogens in indoor environments suggested controlling occupancy,<sup>7,8</sup> ventilation modifications,<sup>9–12</sup> high-efficiency filters and air purifiers,<sup>12–14</sup> and UV air disinfection<sup>15–17</sup> to reduce infection risk. Adopting various control and mitigation measures for airborne pollutants

**Received:** August 24, 2024

**Revised:** November 14, 2024

**Accepted:** November 17, 2024

**Published:** December 16, 2024



ACS Publications

© 2024 The Authors. Co-published by  
Research Center for Eco-Environmental  
Sciences, Chinese Academy of Sciences,  
and American Chemical Society

and pathogens has financial implications. These measures require new or modified systems, potentially with higher energy consumption posing an energy-health trade-off.

The trade-off between a building's energy consumption and thermal comfort is well understood.<sup>18–20</sup> However, including human health adds another layer of complexity requiring optimization between energy, exposure to pollutants and pathogens, and thermal comfort of the occupants.<sup>18,21</sup> The trade-off between energy and well-being has been marginalized by stakeholders such as policymakers, regulators, and rating agencies. A recent study on green and clean buildings argued that technological advances and engineered solutions should be incorporated to modify building design and optimize indoor environment quality (IEQ) and energy use.<sup>22</sup> The buildings of the future need to be designed, constructed, and operated to maximize occupants' well-being while minimizing the associated financial and environmental impacts. Limited research has demonstrated that the gains achieved through improved productivity and reduced sicknesses due to improved indoor air quality might outweigh the costs incurred for energy penalties and system modifications.<sup>3</sup> This work discusses the impact of buildings on human health and the environment and how stakeholders can change the status quo.

## 2. BUILDINGS AND CLIMATE CHANGE

The building and construction sector, an economic growth and development indicator, accounted for 13% of global GDP in 2020. With rapid urbanization, the demand for buildings will increase, and the construction sector is anticipated to grow at an annual average higher than the manufacturing or services sector.<sup>23</sup> By 2030, the revenue generation from this sector is expected to double while remaining the leading sector of the global economy.<sup>23</sup> This rapid growth is accompanied by considerable resource consumption, depleting natural reserves and causing significant environmental impacts. Thus, optimal and judicious usage of resources and energy in building construction and operation is critical for environmental sustainability. Currently, the building and construction sector consumes ~40% of forest timber, ~16% of the world's freshwater, and 40% of all raw materials,<sup>24,25</sup> which is bound to increase as the demand for buildings rises. Regarding environmental impacts, the construction sector contributes to ~23% of air pollution, ~40% of drinking water pollution, and ~50% of landfill waste<sup>26</sup> without accounting for the contributions from building operations.

Furthermore, building construction and operation consumes ~34% of global energy, accounting for ~37% of global energy and process-related carbon emissions.<sup>27</sup> Between 1990 and 2019, global CO<sub>2</sub> emissions from buildings increased by 50%.<sup>28</sup> In this period, population growth, increasing floor area per capita, and increasing carbon intensity of the global energy mix were the leading contributors, accounting for 28%, 52%, and 16% of the global CO<sub>2</sub> emission from buildings, respectively.<sup>28</sup> Additionally, the operational energy use in buildings has been increasing at an average of 1% annually over the past decade.<sup>29</sup> However, an increase of 4% in building energy demand in just two years (2020–22), the largest increase in the past decade, is attributed to the enhanced reliance on natural gas for building operations in emerging economies. This elevated energy demand caused the carbon emissions associated with building operations to reach an all-time high of 10 GtCO<sub>2</sub>.<sup>27</sup> The energy intensity of buildings, i.e., the total final energy consumption per square meter, has

remained constant for the past few years, indicating that the building performance has mostly stayed the same. By 2050, building energy consumption will rise considerably, and research demonstrates decreasing annual heating loads and increasing annual cooling loads owing to climate change,<sup>30</sup> resulting in more energy and carbon-intensive buildings, further exacerbating climate change. This demonstrates a causal loop where building construction and operation, while essential for economic and social development, add to climate change, which in turn governs building design and operation. Besides buildings' operation and resiliency, climate change-induced disturbances and extreme weather events affect occupants' health and well-being. Researchers have associated various climate change parameters with different health impacts, such as infectious disease transmission, mortality, respiratory and cardiovascular ailments, neurological and mental health, and many more. For example, meteorological parameters such as temperature, humidity, and precipitation have been linked with the transmission of vector-borne infectious diseases,<sup>31,32</sup> all-cause and specific-cause mortality,<sup>33–35</sup> and respiratory and cardiovascular ailments.<sup>36</sup> Rocque et al.<sup>37</sup> summarized the research on the health impacts of climate change and established that climate change deteriorates human health. Though the association between climate change and the resultant degree of health deterioration need more research, it can be ascertained that they have detrimental effects on human health, necessitating shielding occupants from ambient conditions and making buildings even more critical. Additionally, the exposure of buildings to climate change-induced disturbances, extreme events, damage, and disruptions will also increase.<sup>38</sup> Therefore, the interaction of buildings with the environment and resiliency factors, such as economic, social, and environmental, should also be analyzed and accounted for.

## 3. INDOOR ENVIRONMENT AND OCCUPANT HEALTH

People spend almost 90% of their time indoors. Therefore, indoor environment quality is critical for occupants' well-being and productivity. Researchers have proposed nine foundations of a healthy building: ventilation, indoor air quality (IAQ), thermal health, water quality, dust and pests, lighting and views, noise, moisture, and safety and security.<sup>39</sup> Although all these elements must be considered for a holistic approach to ensure human well-being and productivity, ventilation, IAQ, and thermal health are the three interdependent factors that have severe implications for occupants' health and buildings' carbon footprint. The interplay between IAQ, thermal health, and ventilation governs the energy-exposure trade-off.<sup>18</sup> Since it is reported that cumulative exposure to airborne pollutants that occurred indoors is comparable to or exceeds outdoors,<sup>40–43</sup> the discussion here primarily focuses on IAQ and its impact on humans.

IAQ is governed by particulate and gaseous pollutants of both indoor origins (from indoor emissions sources) and outdoor origin (from infiltration). Major indoor sources of pollutants include fuel-burning appliances, smoking, cleaning, cooking, building materials, and furnishings.<sup>44</sup> Infiltration of outdoor pollutants depends on the outdoor-indoor air exchange rates. The physicochemical properties of the pollutants govern their transport, transformation, and fate in indoor environments, along with their health impacts. For example, particulate pollutants, termed particulate matter (PM), have varying impacts on human health depending on

their size,<sup>45,46</sup> surface area,<sup>47,48</sup> and chemical composition.<sup>49,50</sup> PM exposure is associated with various health burdens, such as reduced lung function capacity, acute respiratory infections, COPD, asthma, and neurodegenerative diseases.<sup>48,51–54</sup> Recent studies on house observations of microbial and environmental chemistry (HOMEChem) study investigated the impact of everyday activities on the emissions, chemical transformations, and removal of trace gases and particles in indoor air.<sup>55</sup> The study reported cooking as a large source of VOCs, CO<sub>2</sub>, NO<sub>x</sub>, and particles. The cooking particles were predominantly in the ultrafine mode, and organic aerosol dominated the submicron mass. A subsequent HOMEChem study found significantly higher respiratory deposition masses for daily activities (~5x and ~2x more than outdoors during high-emission activities and regular activities, respectively).<sup>56</sup> The same study also found that the particles deposited in the head airways dominated (~75%) total mass deposited except for the high emission activities when the fraction deposited in the alveolar region (~50%) was higher than in the head airways (~39%), owing to the prevalence of ultrafine particles in the total mass. Also, exposure to gaseous pollutants such as NO<sub>x</sub> in residences has been associated with an increased risk of pediatric asthma, and early life NO<sub>x</sub> exposure has also been associated with decreased cognitive function and inattention symptoms.<sup>57,58</sup> Cognitive impairment has also been attributed to high CO<sub>2</sub> concentrations in indoor spaces.<sup>59–61</sup> Additionally, indoor air pollutants and satisfaction with IAQ have been associated with the prevalence of sick building syndrome (SBS) and occupants' productivity.<sup>62–68</sup> Recent cross-sectional studies in multiple countries have linked the prevalence of SBS among residential building occupants with indoor PM concentration, building characteristics, cleaning frequency, and ventilation.<sup>62–65</sup>


Besides pollutant exposure, indoor spaces are major hotspots for airborne disease transmission. Researchers have been studying the indoor transmission of airborne diseases and various strategies to limit the infection risk.<sup>69–71</sup> However, the recently recorded superspreading events of COVID-19 in indoor spaces<sup>72–74</sup> gave renewed impetus to the research on sources, transport, and the fate of bioaerosols in the indoor environment. These studies are laying the ground for including such biohazards in building design and operation strategies. Recent studies have suggested high air filtration efficiency and intermeeting break times for offices,<sup>75</sup> improved ventilation rates, controlled air recirculation, and reduced number of people in an enclosed space to prevent airborne disease transmission.<sup>76</sup> However, increased ventilation rates increase energy consumption associated with HVAC operation.<sup>77,78</sup> A computational study conducted for 13 cities in the USA representing a range of ambient climate conditions demonstrated that the airborne infection risk is reduced by supplying 100% outdoor air, which also led to an average 45% increase in energy consumption.<sup>78</sup> The same study demonstrated that filtration could result in 31% lower energy consumption while also lowering the infection probability by 29% relative to the 100% outdoor air ventilation case. Although improving filtration has some associated energy penalties, it is significantly lower than supplying 100% outdoor air. Therefore, filtration and ventilation can be conjugated to reduce exposure to airborne pathogens and pollutants in indoor environments while minimizing associated energy penalties. Another study proposed a dynamic optimization strategy for indoor PM control while ensuring the thermal comfort of the occupants.<sup>18</sup>

The study reported varying degrees of exposure reduction and energy penalty depending on the importance assigned during their optimization, thus highlighting the inherent trade-off. The same study also demonstrated diminishing marginal returns in terms of exposure reduction for every unit of additional energy consumption and defined normalized exposure reduction (percentage exposure reduction normalized by the percentage increase in energy consumption) to quantify and compare the trade-off in different scenarios.<sup>18</sup> However, as elaborated in the next section, such exposure-energy trade-offs are yet to be recognized and accounted for in the current building standards and rating protocols.

#### 4. CURRENT ASSESSMENT SCHEMES FOR BUILDING SUSTAINABILITY AND OCCUPANTS' WELL-BEING

Mandatory building structure codes and regulations for construction practices have been developed and enforced worldwide as they directly affect safety. However, there are no such regulations to assess the sustainability of buildings. Multiple nonmandatory frameworks, commonly termed Green Building Rating Schemes (GBRS), have been developed globally, such as LEED (Leadership in Energy and Environmental Design) in the USA, BREEAM (Building Research Establishment Environmental Assessment Method) in the UK, CASBEE (Comprehensive Assessment System for Built Environment Efficiency) in Japan, 3-Star system in China, and GRIHA (Green Rating for Integrated Habitat Assessment) and IGBC (Indian Green Building Council) rating system in India. These GBRSs are based on multicriteria assessment of environmentally, socially, and economically sustainable practices in building design, construction, and operation. Each GBRS has different assessment categories and weightage allocations.<sup>25,79</sup> The most common assessment criteria in GBRSs are comfort, energy, environmental awareness, materials, natural resources, climate change, waste, and water. Gonzalo et al. analyzed the eight most popular GBRSs from different countries and reported the average weightages for different criteria - comfort and well-being (28.5%), natural resources and climate change (27.9%), energy (12.3%), materials (10.9%), water (8.5%), waste (6.9%), and environmental awareness (5%).<sup>80</sup> Although comfort and well-being are allocated the maximum weightage, it is critical to understand their constituent factors. Most GBRSs measure comfort and well-being based on indoor environment quality (IEQ), proximity to transport facilities, privacy, efficient usage of space and accessibility, noise, and lighting.<sup>80</sup> Within the IEQ category, GBRSs usually assign minimal weightage to IAQ, and airborne pathogen transmission is not even considered apart from indirectly governed by ventilation. On average, the weightage of IAQ in these rating schemes is 7.5%, and volatile organic compounds (VOCs), CO<sub>2</sub>, and formaldehyde are the commonly considered indoor pollutants.<sup>81</sup> VOCs and formaldehyde are allocated a certain weightage, requiring the use of low-VOC products such as paints and furnishing materials. However, continuous monitoring and measures to reduce indoor concentrations usually fall beyond the scope of GBRSs. Furthermore, most IAQ-based evaluations in the current GBRSs are performed during preoccupancy. Therefore, critical emission sources introduced postoccupancy during the operational phase of the buildings, and their impacts on IAQ are not considered. Moreover, the health implications and well-being in the indoor environment go well beyond these few pollutants. Globally, some organizations have recommended





**Figure 1.** Currently fragmented building rating protocols, highlighting the need for comprehensive framework for building assessment to ensure health and sustainability.

IAQ and ventilation requirements in buildings, such as ASHRAE 62.1 (Ventilation and Acceptable Indoor Air Quality), ASHRAE 62.2 (Ventilation and Acceptable Indoor Air Quality in Residential Buildings), and WHO indoor air quality guidelines. However, these are guidelines, not regulations; thus, they are not mandatory. A recent study by more than 40 scientists advocated for mandatory indoor air quality guidelines for public buildings and recommended concentrations of  $\text{PM}_{2.5}$ ,  $\text{CO}_2$ , CO, and ventilation rates while arguing that if some countries lead by example, IAQ standards will become normalized.<sup>82</sup>

The energy-IAQ trade-offs, lack of standardization of IAQ-related metrics, and missing focus on airborne disease transmission in GBRs reflect their lack of comprehensiveness, especially regarding health and well-being. Currently, GBRs focus primarily on environmental aspects, with an average of more than 68% weightage assigned to indicators related to environmental sustainability.<sup>80</sup> Additionally, of all the stages in a building's life, more than 58% weightage is allocated to the building design stage. The use stage of a building only accounts for about 30% of weightage, while the environmental, social, and health impacts outweigh that during the design stage.<sup>80</sup> Besides GBRs and IAQ guidelines, some countries have formulated building energy codes to improve energy efficiency and reduce carbon emissions.<sup>83</sup> Compliance with these codes varies among countries; some countries, such as Australia, Germany, France, and Spain, have made them mandatory for residential as well as commercial buildings. These codes are not enforced nationally in other countries, including India, China, and the USA. Existing IAQ guidelines, GBRs, and energy codes target well-being, sustainability, and energy, usually focusing on only one with little consideration for other aspects. This fragmentation must be addressed as well-being, sustainability, and energy usually pose trade-offs.

Considering that the building and construction sector is among the largest contributors to global emissions, holistic frameworks for benchmarking and assessing building performance, resource utilization, and energy efficiency while safeguarding occupants' health are imperative. Considerable research is being done on nearly zero and net-zero energy buildings.<sup>84–88</sup> However, such studies fail to incorporate how interventions that make building low or net-zero energy affect the health and well-being of its occupants. An interim step toward making buildings net-zero or nearly zero energy is creating benchmarks and performance standards for existing buildings. Recent studies have demonstrated that ensuring thermal comfort while reducing exposure comes at an energy

penalty.<sup>18,89,90</sup> Thus, the trade-off must be accounted for in energy benchmarking scenarios. Developing building codes and standards that account for embodied and operational consumption along with energy-exposure-comfort trade-off will ensure the integration of the life cycle approach. Apart from codes and standards, technical and scientific interventions such as onsite renewable energy generation, intelligent control algorithms (predictive control, artificial intelligence, and others) to optimize ventilation and energy-exposure trade-offs, energy-efficient and acoustic lights, and appliance scheduling could be crucial to promoting net-zero buildings. The control algorithms, such as model predictive control and reinforcement learning, could be designed to control multiple comfort and health parameters for adaptive and occupancy-based air conditioning operations, dynamic set temperature of the HVAC system, and variable indoor-outdoor air exchange. Ultimately, there is a need to take a step further in the design and operation of the buildings of the future that are low or net-zero energy while also promoting health and well-being by shielding occupants from airborne pollutants and pathogens. Figure 1 summarizes the current practices for assessment of building sustainability, existing fragmentation, and the need for a comprehensive framework for sustainable and healthy buildings.

## 5. CONCLUSION

This work discusses and identifies the gaps in the current approach for environmentally sustainable buildings that also ensure the health and well-being of its occupants. The building and construction sector abides by different mandatory regulations and codes, such as structural integrity and fire safety. However, compliance with the regulations and guidelines on aspects such as energy, comfort, and well-being vary by country, with limited focus on factors such as indoor air quality and transmission of airborne diseases. GBRs, the most popular for building certifications, primarily measure the environmental sustainability of buildings. A diverse set of codes, guidelines, and certification schemes has led to a fragmented approach toward designing, constructing, and operating sustainable and healthy buildings.

The quantifiable metrics, such as energy and carbon footprints of building construction and operation, are critical and adequately considered, as evident by the dominance of these metrics in GBRs and other building codes. However, critical but challenging to quantify metrics, such as buildings' impact on occupants' health, well-being, and productivity, must be integrated into GBRs and building codes for sustainable

and healthy buildings. GBRs and building codes accounting for the currently overlooked trade-off between IAQ, energy, comfort, and well-being are imperative to incentivize the transition from green buildings to green and healthy buildings. Filling these gaps will require rethinking how we design, operate, and assess buildings using existing and yet-to-be-developed technology, policies, and regulations. Buildings of the future ensuring occupant health, comfort, and well-being, along with lower energy and carbon footprint, will require affordable real-time monitoring systems, intelligent control algorithms, advanced air purification techniques, and sustainable building materials.

The advances in low-cost sensors (LCSs) for measuring pollutants and comfort parameters such as temperature, relative humidity, illuminance, and acoustic comfort are critical for real-time monitoring of indoor environment quality as the first step toward safeguarding the health and well-being of building occupants. The real-time measurements from sensors can be fed to different control algorithms for real-time control of HVAC systems to optimize energy, exposure, and comfort. Furthermore, continuous monitoring can also be utilized for early warning systems in case of hazards. Integrating LCSs in buildings could provide crucial information on various emission activities, exposure scenarios, occupancy levels, and comfort conditions that could help take corrective measures to improve indoor environment quality while also minimizing the associated carbon footprint. However, the reliability and accuracy of LCSs for pollutant monitoring remain challenging. LCSs need more robust calibration and testing under different climatic and operating conditions to ensure reliability. For example, low-cost PM sensors, operating on the principle of light scattering, have demonstrated higher accuracy in sensing ultrafine particles in a size range of less than 1  $\mu\text{m}$ . In contrast, these sensors perform poorly for coarse and fine particles ( $\text{PM}_{10}$  and  $\text{PM}_{2.5}$ ).<sup>91,92</sup> In summary, LCSs will undoubtedly play a significant role in ensuring occupants' health, but the field still needs more research. Apart from sensing, mitigation and control of indoor pollutants and pathogens are critical to improving IAQ, lowering contamination probability, and improving occupants' health. The advent of artificial intelligence and its capability could be a key to learning the dynamics of varying indoor environments for building operations and intelligent control. Researchers have proposed various control algorithms, such as model predictive control,<sup>93</sup> dynamic optimization,<sup>18</sup> and reinforcement learning,<sup>94,95</sup> that have shown great potential to learn the dynamics of the indoor environment and for varied applications ranging from controlling HVAC systems to creating decision support systems.

Furthermore, a benchmarking framework must be developed for building energy consumption and performance encompassing occupants' health and well-being metrics. Such benchmarks should account for geographical variations in resource availability, their carbon intensity, and perceived comfort conditions. Ultimately, policymakers and governments must recognize the existing gaps, and multidisciplinary stakeholders must collaborate to develop comprehensive frameworks for the building of the future. Finally, the goal should be securing equity in a healthy and comfortable environment for occupants while minimizing its impact on the environment.

## AUTHOR INFORMATION

### Corresponding Author

**Sameer Patel** – Department of Civil Engineering, Indian Institute of Technology Gandhinagar, Palaj, Gandhinagar, Gujarat 382355, India; Department of Chemical Engineering and Kiran C. Patel Centre for Sustainable Development, Indian Institute of Technology Gandhinagar, Palaj, Gandhinagar, Gujarat 382355, India; [orcid.org/0000-0002-9293-9546](https://orcid.org/0000-0002-9293-9546); Email: [sameer.patel@iitgn.ac.in](mailto:sameer.patel@iitgn.ac.in)

### Author

**Nishchaya Kumar Mishra** – Department of Civil Engineering, Indian Institute of Technology Gandhinagar, Palaj, Gandhinagar, Gujarat 382355, India

Complete contact information is available at:

<https://pubs.acs.org/10.1021/envhealth.4c00161>

### Notes

The authors declare no competing financial interest.

### Biography



**Sameer Patel** is an Assistant Professor jointly appointed in the Department of Chemical Engineering and Civil Engineering at the Indian Institute of Technology (IIT) Gandhinagar, India. His research focuses on the nexus of energy, environment, and exposure in built environments, encompassing multidisciplinary work on low-cost instrumentation, aerosols, air quality, renewable energy integration, solutions for optimizing indoor air quality and energy consumption, and development of comprehensive frameworks for building assessment and certification. He received his Ph.D. from Washington University in Saint Louis and then conducted postdoctoral research at the University of Colorado Boulder before joining IIT Gandhinagar.

## ACKNOWLEDGMENTS

This work was supported by the Ministry of Education, GoI (Grant AICoE/2024/AIS/2100000017), and the Science and Engineering Research Board (SERB), Department of Science and Technology, GoI (Grant SRG/2021/1001050). Partial funding from the Indian Institute of Technology Gandhinagar is also acknowledged.

## ABBREVIATIONS

ASHRAE American Society of Heating, Refrigerating and Air-Conditioning Engineers

BREEAM Building Research Establishment Environmental Assessment Method

CASBEE	Comprehensive Assessment System for Built Environment Efficiency
COPD	Chronic Obstructive Pulmonary Disease
COVID	Coronavirus Disease
GBRS	Green Building Rating Scheme
GDP	Gross Domestic Product
GRIHA	Green Rating for Integrated Habitat Assessment
GtCO <sub>2</sub>	Gigatonnes Carbon Dioxide
HAP	Household Air Pollutant
HVAC	Heating, Ventilation, and Air Conditioning
IAP	Indoor Air Pollutant
IAQ	Indoor Air Quality
IEQ	Indoor Environment Quality
IGBC	Indian Green Building Council
LEED	Leadership in Energy and Environmental Design
PM	Particulate Matter
UV	Ultraviolet
VOC	Volatile Organic Compounds

## REFERENCES

- (1) Pheng, L. S.; Hou, L. S. The Economy and the Construction Industry. *Construction Quality and the Economy* **2019**, 21–54.
- (2) Goldstein, A. H.; Nazaroff, W. W.; Weschler, C. J.; Williams, J. How Do Indoor Environments Affect Air Pollution Exposure? *Environ. Sci. Technol.* **2021**, 55 (1), 100–108.
- (3) Allen, J. G.; Macomber, J. D. *Healthy Buildings: How Indoor Space Can Make You Sick or Keep You Well*; Revised and updated edition; Harvard University Press: Cambridge, MA, 2022.
- (4) Wan, K. K. W.; Li, D. H. W.; Pan, W.; Lam, J. C. Impact of Climate Change on Building Energy Use in Different Climate Zones and Mitigation and Adaptation Implications. *Appl. Energy* **2012**, 97, 274–282.
- (5) Röck, M.; Saade, M. R. M.; Balouktsi, M.; Rasmussen, F. N.; Birgisdottir, H.; Frischknecht, R.; Habert, G.; Lützkendorf, T.; Passer, A. Embodied GHG Emissions of Buildings - The Hidden Challenge for Effective Climate Change Mitigation. *Appl. Energy* **2020**, 258, 114107.
- (6) Thakur, A. K.; Patel, S. Indoor Air Quality in Urban India: Current Status, Research Gap, and the Way Forward. *Environ. Sci. Technol. Lett.* **2023**, 10 (12), 1146–1158.
- (7) XU, Y.; CAI, J.; LI, S.; HE, Q.; ZHU, S. Airborne Infection Risks of SARS-CoV-2 in U.S. Schools and Impacts of Different Intervention Strategies. *Sustain Cities Soc.* **2021**, 74, 103188.
- (8) Sun, C.; Zhai, Z. The Efficacy of Social Distance and Ventilation Effectiveness in Preventing COVID-19 Transmission. *Sustain Cities Soc.* **2020**, 62, 102390.
- (9) Lin, Y.; Wang, J.; Yang, W.; Tian, L.; Candido, C. A Systematic Review on COVID-19 Related Research in HVAC System and Indoor Environment. *Energy and Built Environment* **2024**, 5, 970.
- (10) Rayegan, S.; Shu, C.; Berquist, J.; Jeon, J.; Zhou, L. Grace; Wang, L. Leon; Mbareche, H.; Tardif, P.; Ge, H. A Review on Indoor Airborne Transmission of COVID-19- Modelling and Mitigation Approaches. *Journal of Building Engineering* **2023**, 64, 105599.
- (11) Morawska, L.; Allen, J.; Bahnfleth, W.; Bluyssen, P. M.; Boerstra, A.; Buonanno, G.; Cao, J.; Dancer, S. J.; Floto, A.; Franchimon, F.; Greenhalgh, T.; Haworth, C.; Hogeling, J.; Ison, C.; Jimenez, J. L.; Kurnitski, J.; Li, Y.; Loomans, M.; Marks, G.; Marr, L. C.; Mazzarella, L.; Melikov, A. K.; Miller, S.; Milton, D. K.; Nazaroff, W.; Nielsen, P. V.; Noakes, C.; Peccia, J.; Prather, K.; Querol, X.; Sekhar, C.; Seppänen, O.; Tanabe, S. I.; Tang, J. W.; Tellier, R.; Tham, K. W.; Wargocki, P.; Wierzbicka, A.; Yao, M. A Paradigm Shift to Combat Indoor Respiratory Infection. *Science* **2021**, 372 (6543), 689–691.
- (12) Faulkner, C. A.; Castellini, J. E.; Zuo, W.; Lorenzetti, D. M.; Sohn, M. D. Investigation of HVAC Operation Strategies for Office Buildings during COVID-19 Pandemic. *Build Environ* **2022**, 207, 108519.
- (13) Katal, A.; Albettar, M.; Wang, L. Leon City Reduced Probability of Infection (CityRPI) for Indoor Airborne Transmission of SARS-CoV-2 and Urban Building Energy Impacts. *medRxiv* **2021**, DOI: 10.1101/2021.01.19.21250046.
- (14) Bohanon, H.; Zaatari, P. E. Effect of Ventilation And Filtration on Viral Infection in Residences. *ASHRAE Journal* **2020**, 62 (12), 38–45.
- (15) Feng, Y.; Zhao, J.; Spinolo, M.; Lane, K.; Leung, D.; Marshall, D.; Mlinaric, P. Assessing the Filtration Effectiveness of a Portable Ultraviolet Air Cleaner on Airborne SARS-CoV-2 Laden Droplets in a Patient Room: A Numerical Study. *Aerosol Air Qual Res.* **2021**, 21 (5), 200608.
- (16) Buchan, A. G.; Yang, L.; Atkinson, K. D. Predicting Airborne Coronavirus Inactivation by Far-UVC in Populated Rooms Using a High-Fidelity Coupled Radiation-CFD Model. *Scientific Reports* **2020**, 10 (1), 1–7.
- (17) Srivastava, S.; Zhao, X.; Manay, A.; Chen, Q. Effective Ventilation and Air Disinfection System for Reducing Coronavirus Disease 2019 (COVID-19) Infection Risk in Office Buildings. *Sustain Cities Soc.* **2021**, 75, 103408.
- (18) Mishra, N. K.; Vance, M. E.; Novoselac, A.; Patel, S. Dynamic Optimization of Personal Exposure and Energy Consumption While Ensuring Thermal Comfort in a Test House. *Build Environ* **2024**, 252, 111265.
- (19) Hou, F.; Ma, J.; Kwok, H. H. L.; Cheng, J. C. P. Prediction and Optimization of Thermal Comfort, IAQ and Energy Consumption of Typical Air-Conditioned Rooms Based on a Hybrid Prediction Model. *Build Environ* **2022**, 225, 109576.
- (20) Karyono, K.; Abdullah, B. M.; Cotgrave, A. J.; Bras, A. The Adaptive Thermal Comfort Review from the 1920s, the Present, and the Future. *Developments in the Built Environment* **2020**, 4, 100032.
- (21) Faulkner, C. A.; Castellini, J. E.; Lou, Y.; Zuo, W.; Lorenzetti, D. M.; Sohn, M. D. Tradeoffs among Indoor Air Quality, Financial Costs, and CO<sub>2</sub> Emissions for HVAC Operation Strategies to Mitigate Indoor Virus in U.S. Office Buildings. *Build Environ* **2022**, 221, 109282.
- (22) Marr, L. C.; Cappa, C. D.; Bahnfleth, W. P.; Bertram, T. H.; Corsi, R. L.; Ellis, M. J.; Henze, G. P.; Isaacman-VanWertz, G.; Miller, S. L.; Pistochini, T.; Ristenpart, W. D.; Vance, M. E.; Vikesland, P. J. Toward Clean and Green Buildings. *J. Environ. Eng.* **2024**, 150 (9), 02524002.
- (23) Robinson, G.; Leonard, J.; Whittington, T. *Future of Construction: A Global Forecast for Construction to 2030*; Marsh & Guy Carpenter, Oxford Economics, 2021. <https://www.marsh.com/en/industries/construction/insights/the-future-of-construction.html> (accessed 2024-11-09).
- (24) *Resource demands of the built environment*; The Encyclopedia of World Problems & Human Potential; UIA, 2000; <http://encyclopedia.uia.org/en/problem/resource-demands-built-environment/> (accessed 2023-12-05).
- (25) Doan, D. T.; Ghaffarianhoseini, A.; Naismith, N.; Zhang, T.; Ghaffarianhoseini, A.; Tookey, J. A Critical Comparison of Green Building Rating Systems. *Build Environ* **2017**, 123, 243–260.
- (26) *How Does Construction Affect The Environment?*; ARCHDESK, 2021; <https://archdesk.com/blog/how-does-construction-affect-the-environment/> (accessed 2023-12-05).
- (27) 2022 Global Status Report for Buildings and Construction: Towards a Zero-emission, Efficient and Resilient Buildings and Construction Sector; United Nations Environment Programme, 2022.
- (28) Buildings. *Climate Change 2022 - Mitigation of Climate Change* **2023**, 953–1048.
- (29) *World Energy Outlook 2023*; International Energy Agency, 2023; <https://iea.blob.core.windows.net/assets/86ede39e-4436-42d7-ba2a-edf61467e070/WorldEnergyOutlook2023.pdf> (accessed 2024-11-09).
- (30) Gerçek, M.; Durmuş Arsan, Z. Energy and Environmental Performance Based Decision Support Process for Early Design Stages of Residential Buildings under Climate Change. *Sustain Cities Soc.* **2019**, 48, 101580.



- (31) Wang, Y.; Xu, C.; Ren, J.; Zhao, Y.; Li, Y.; Wang, L.; Yao, S. The Long-Term Effects of Meteorological Parameters on Pertussis Infections in Chongqing, China, 2004–2018. *Scientific Reports* 2020 10:1 **2020**, 10 (1), 1–12.
- (32) Dhimal, M.; Ahrens, B.; Kuch, U. Climate Change and Spatiotemporal Distributions of Vector-Borne Diseases in Nepal - A Systematic Synthesis of Literature. *PLoS One* **2015**, 10 (6), e0129869.
- (33) Ballester, J.; Quijal-Zamorano, M.; Méndez Turrubiates, R. F.; Pegenaute, F.; Herrmann, F. R.; Robine, J. M.; Basagaña, X.; Tonne, C.; Antó, J. M.; Achebak, H. Heat-Related Mortality in Europe during the Summer of 2022. *Nature Medicine* 2023 29:7 **2023**, 29 (7), 1857–1866.
- (34) de Bont, J.; Nori-Sarma, A.; Stafoggia, M.; Banerjee, T.; Ingole, V.; Jaganathan, S.; Mandal, S.; Rajiva, A.; Krishna, B.; Kloog, I.; Lane, K.; Mall, R. K.; Tiwari, A.; Wei, Y.; Wellenius, G. A.; Prabhakaran, D.; Schwartz, J.; Prabhakaran, P.; Ljungman, P. Impact of Heatwaves on All-Cause Mortality in India: A Comprehensive Multi-City Study. *Environ. Int.* **2024**, 184, 108461.
- (35) Campbell, S.; Remenyi, T. A.; White, C. J.; Johnston, F. H. Heatwave and Health Impact Research: A Global Review. *Health Place* **2018**, 53, 210–218.
- (36) Kotecki, P.; Więckowska, B.; Stawińska-Witoszyńska, B. The Impact of Meteorological Parameters and Seasonal Changes on Reporting Patients with Selected Cardiovascular Diseases to Hospital Emergency Departments: A Pilot Study. *International Journal of Environmental Research and Public Health* 2023, Vol. 20, Page 4838 **2023**, 20 (6), 4838.
- (37) Rocque, R. J.; Beaudoin, C.; Ndjaboue, R.; Cameron, L.; Poirier-Bergeron, L.; Poulin-Rheault, R. A.; Fallon, C.; Tricco, A. C.; Witteman, H. O. Health Effects of Climate Change: An Overview of Systematic Reviews. *BMJ. Open* **2021**, 11 (6), e046333.
- (38) Al-Humaiqani, M. M.; Al-Ghamdi, S. G. The Built Environment Resilience Qualities to Climate Change Impact: Concepts, Frameworks, and Directions for Future Research. *Sustain Cities Soc.* **2022**, 80, 103797.
- (39) Allen, J. G.; Bernstein, A.; Sita, E.; Flanagan, S.; Gokhale, M.; Goodman, J. M.; Klager, S.; Klingensmith, L.; Guillermo, J.; Laurent, C.; Lockley, S. W.; Macnaughton, P.; Pakpour, S.; Spengler, J. D.; Vallarino, J.; Williams, A.; Young, A.; Yin, J.; Chan, H. T. H. *The 9 Foundations of a Healthy Building*; Harvard School of Public Health (forhealth.org), 2017.
- (40) Morawska, L.; Afshari, A.; Bae, G. N.; Buonanno, G.; Chao, C. Y. H.; Hänninen, O.; Hofmann, W.; Isaxon, C.; Jayaratne, E. R.; Pasanen, P.; Salthammer, T.; Waring, M.; Wierzbicka, A. Indoor Aerosols: From Personal Exposure to Risk Assessment. *Indoor Air* **2013**, 23 (6), 462–487.
- (41) Azimi, P.; Stephens, B. A Framework for Estimating the US Mortality Burden of Fine Particulate Matter Exposure Attributable to Indoor and Outdoor Microenvironments. *Journal of Exposure Science & Environmental Epidemiology* 2018 30:2 **2020**, 30 (2), 271–284.
- (42) Wallace, L. A.; Zhao, T.; Klepeis, N. E. Indoor Contribution to PM<sub>2.5</sub> Exposure Using All PurpleAir Sites in Washington, Oregon, and California. *Indoor Air* **2022**, 32 (9), e13105.
- (43) Lunderberg, D. M.; Liang, Y.; Singer, B. C.; Apte, J. S.; Nazaroff, W. W.; Goldstein, A. H. Assessing Residential PM<sub>2.5</sub> Concentrations and Infiltration Factors with High Spatiotemporal Resolution Using Crowdsourced Sensors. *Proc. Natl. Acad. Sci. U. S. A.* **2023**, 120 (50), e2308832120.
- (44) *Indoor Air Quality*; US EPA, 2023; <https://www.epa.gov/report-environment/indoor-air-quality> (accessed 2023-05-11).
- (45) Sicard, P.; Khaniabadi, Y. O.; Perez, S.; Gualtieri, M.; De Marco, A. Effect of O<sub>3</sub>, PM<sub>10</sub> and PM<sub>2.5</sub> on Cardiovascular and Respiratory Diseases in Cities of France, Iran and Italy. *Environmental Science and Pollution Research* **2019**, 26 (31), 32645–32665.
- (46) Flood-Garibay, J. A.; Angulo-Molina, A.; Méndez-Rojas, M. Á. Particulate Matter and Ultrafine Particles in Urban Air Pollution and Their Effect on the Nervous System. *Environ. Sci. Process Impacts* **2023**, 25, 704.
- (47) Karakoçak, B. B.; Raliya, R.; Davis, J. T.; Chavalmane, S.; Wang, W. N.; Ravi, N.; Biswas, P. Biocompatibility of Gold Nanoparticles in Retinal Pigment Epithelial Cell Line. *Toxicology in Vitro* **2016**, 37, 61–69.
- (48) Patel, S.; Leavey, A.; Sheshadri, A.; Kumar, P.; Kandikuppa, S.; Tarsi, J.; Mukhopadhyay, K.; Johnson, P.; Balakrishnan, K.; Schechtman, K. B.; Castro, M.; Yadama, G.; Biswas, P. Associations between Household Air Pollution and Reduced Lung Function in Women and Children in Rural Southern India. *Journal of Applied Toxicology* **2018**, 38 (11), 1405–1415.
- (49) Bates, J. T.; Weber, R. J.; Abrams, J.; Verma, V.; Fang, T.; Klein, M.; Strickland, M. J.; Sarnat, S. E.; Chang, H. H.; Mulholland, J. A.; Tolbert, P. E.; Russell, A. G. Reactive Oxygen Species Generation Linked to Sources of Atmospheric Particulate Matter and Cardiorespiratory Effects. *Environ. Sci. Technol.* **2015**, 49 (22), 13605–13612.
- (50) He, L.; Zhang, J. Particulate Matter (PM) Oxidative Potential: Measurement Methods and Links to PM Physicochemical Characteristics and Health Effects. *Crit. Rev. Environ. Sci. Technol.* **2023**, 53 (2), 177–197.
- (51) James, B. S.; Shetty, R. S.; Kamath, A.; Shetty, A. Household Cooking Fuel Use and Its Health Effects among Rural Women in Southern India—A Cross-Sectional Study. *PLoS One* **2020**, 15 (4), e0231757.
- (52) Amouei Torkmahalleh, M.; Naseri, M.; Nurzhan, S.; Gabdrashova, R.; Bekezhankyzy, Z.; Gimnkhani, A.; Malekipirbazari, M.; Jouzizadeh, M.; Tabesh, M.; Farrokhi, H.; Mehri-Dehnavi, H.; Khanbabaie, R.; Sadeghi, S.; Khatir, A. A.; Sabanov, S.; Buonanno, G.; Hopke, P. K.; Cassee, F.; Crape, B. Human Exposure to Aerosol from Indoor Gas Stove Cooking and the Resulting Nervous System Responses. *Indoor Air* **2022**, 32 (2), e12983.
- (53) Gan, W.; Manning, K. J.; Cleary, E. G.; Fortinsky, R. H.; Brugge, D. Exposure to Ultrafine Particles and Cognitive Decline among Older People in the United States. *Environ. Res.* **2023**, 227, 115768.
- (54) Calderón-Garcidueñas, L.; Ayala, A. Air Pollution, Ultrafine Particles, and Your Brain: Are Combustion Nanoparticle Emissions and Engineered Nanoparticles Causing Preventable Fatal Neurodegenerative Diseases and Common Neuropsychiatric Outcomes? *Environ. Sci. Technol.* **2022**, 56 (11), 6847–6856.
- (55) Farmer, D. K.; Vance, M. E.; Abbott, J. P. D.; Abeleira, A.; Alves, M. R.; Arata, C.; Boedicker, E.; Bourne, S.; Cardoso-Saldaña, F.; Corsi, R.; Decarlo, P. F.; Goldstein, A. H.; Grassian, V. H.; Hildebrandt Ruiz, L.; Jimenez, J. L.; Kahan, T. F.; Katz, E. F.; Mattila, J. M.; Nazaroff, W. W.; Novoselac, A.; O'Brien, R. E.; Or, V. W.; Patel, S.; Sankhyani, S.; Stevens, P. S.; Tian, Y.; Wade, M.; Wang, C.; Zhou, S.; Zhou, Y. Overview of HOMEchem: House Observations of Microbial and Environmental Chemistry. *Environ. Sci. Process Impacts* **2019**, 21 (8), 1280–1300.
- (56) Patel, S.; Sankhyani, S.; Boedicker, E. K.; Decarlo, P. F.; Farmer, D. K.; Goldstein, A. H.; Katz, E. F.; Nazaroff, W. W.; Tian, Y.; Vanhanen, J.; Vance, M. E. Indoor Particulate Matter during HOMEchem: Concentrations, Size Distributions, and Exposures. *Environ. Sci. Technol.* **2020**, 54 (12), 7107–7116.
- (57) Morales, E.; Julvez, J.; Torrent, M.; De Cid, R.; Guxens, M.; Bustamante, M.; Künzli, N.; Sunyer, J. Association of Early-Life Exposure to Household Gas Appliances and Indoor Nitrogen Dioxide With Cognition and Attention Behavior in Preschoolers. *Am. J. Epidemiol.* **2009**, 169 (11), 1327–1336.
- (58) Belanger, K.; Holford, T. R.; Gent, J. F.; Hill, M. E.; Kezik, J. M.; Leaderer, B. P. Household Levels of Nitrogen Dioxide and Pediatric Asthma Severity. *Epidemiology* **2013**, 24 (2), 320.
- (59) Du, B.; Tandoc, M. C.; Mack, M. L.; Siegel, J. A. Indoor CO<sub>2</sub> Concentrations and Cognitive Function: A Critical Review. *Indoor Air* **2020**, 30 (6), 1067–1082.
- (60) Chen, D.; Huebner, G.; Bagkeris, E.; Ucci, M.; Mumovic, D. Effects of Exposure to Moderate Pure Carbon Dioxide Levels on Cognitive Performance, Acute Health Symptoms and Perceived

Indoor Environment Quality. *Building Environment* **2023**, *245*, 110967.

(61) González-Martín, J.; Kraakman, N. J. R.; Pérez, C.; Lebrero, R.; Muñoz, R. A State-of-the-Art Review on Indoor Air Pollution and Strategies for Indoor Air Pollution Control. *Chemosphere* **2021**, *262*, 128376.

(62) Huo, X.; Sun, Y.; Hou, J.; Wang, P.; Kong, X.; Zhang, Q.; Sundell, J. Sick Building Syndrome Symptoms among Young Parents in Chinese Homes. *Build Environ* **2020**, *169*, 106283.

(63) Azuma, K.; Ikeda, K.; Kagi, N.; Yanagi, U.; Osawa, H. Prevalence and Risk Factors Associated with Nonspecific Building-Related Symptoms in Office Employees in Japan: Relationships between Work Environment, Indoor Air Quality, and Occupational Stress. *Indoor Air* **2015**, *25* (5), 499–511.

(64) Smedje, G.; Wang, J.; Norbäck, D.; Nilsson, H.; Engvall, K. SBS Symptoms in Relation to Dampness and Ventilation in Inspected Single-Family Houses in Sweden. *Int. Arch Occup Environ. Health* **2017**, *90* (7), 703–711.

(65) Shao, Z.; Bi, J.; Yang, J.; Ma, Z. Indoor PM<sub>2.5</sub>, Home Environmental Factors and Lifestyles Are Related to Sick Building Syndrome among Residents in Nanjing, China. *Build Environ* **2023**, *235*, 110204.

(66) Dimitroulopoulou, S.; Dudzińska, M. R.; Gunnarsen, L.; Hägerhed, L.; Maula, H.; Singh, R.; Toyinbo, O.; Haverinen-Shaughnessy, U. Indoor Air Quality Guidelines from across the World: An Appraisal Considering Energy Saving, Health, Productivity, and Comfort. *Environ. Int.* **2023**, *178*, 108127.

(67) Felgueiras, F.; Mourão, Z.; Moreira, A.; Gabriel, M. F. Indoor Environmental Quality in Offices and Risk of Health and Productivity Complaints at Work: A Literature Review. *Journal of Hazardous Materials Advances* **2023**, *10*, 100314.

(68) Zhang, X.; Du, J.; Chow, D. Association between Perceived Indoor Environmental Characteristics and Occupants' Mental Well-Being, Cognitive Performance, Productivity, Satisfaction in Workplaces: A Systematic Review. *Build Environ* **2023**, *246*, 110985.

(69) Chen, S. C.; Chang, C. F.; Liao, C. M. Predictive Models of Control Strategies Involved in Containing Indoor Airborne Infections. *Indoor Air* **2006**, *16* (6), 469–481.

(70) Li, Y.; Leung, G. M.; Tang, J. W.; Yang, X.; Chao, C. Y. H.; Lin, J. Z.; Lu, J. W.; Nielsen, P. V.; Niu, J.; Qian, H.; Sleight, A. C.; Su, H. J. J.; Sundell, J.; Wong, T. W.; Yuen, P. L. Role of Ventilation in Airborne Transmission of Infectious Agents in the Built Environment - a Multidisciplinary Systematic Review. *Indoor Air* **2007**, *17* (1), 2–18.

(71) Tung, Y. C.; Hu, S. C. Infection Risk of Indoor Airborne Transmission of Diseases in Multiple Spaces. *Archit Sci. Rev.* **2008**, *51* (1), 14–20.

(72) Majra, D.; Benson, J.; Pitts, J.; Stebbing, J. SARS-CoV-2 (COVID-19) Superspreader Events. *Journal of Infection* **2021**, *82* (1), 36–40.

(73) Guo, Y.; Li, X.; Luby, S.; Jiang, G. Vertical Outbreak of COVID-19 in High-Rise Buildings: The Role of Sewer Stacks and Prevention Measures. *Curr. Opin Environ. Sci. Health* **2022**, *29*, 100379.

(74) Park, S. Y.; Kim, Y. M.; Yi, S.; Lee, S.; Na, B. J.; Kim, C. B.; Kim, J. Il; Kim, H. S.; Kim, Y. B.; Park, Y.; Huh, I. S.; Kim, H. K.; Yoon, H. J.; Jang, H.; Kim, K.; Chang, Y.; Kim, I.; Lee, H.; Gwack, J.; Kim, S. S.; Kim, M.; Kwon, S.; Choe, Y. J.; Park, O.; Park, Y. J.; Jeong, E. K. Coronavirus Disease Outbreak in Call Center, South Korea. *Emerg Infect Dis* **2020**, *26* (8), 1666.

(75) Dixit, A. K.; Espinoza, B.; Qiu, Z.; Vullikanti, A.; Marathe, M. V. Airborne Disease Transmission during Indoor Gatherings over Multiple Time Scales: Modeling Framework and Policy Implications. *Proc. Natl. Acad. Sci. U. S. A.* **2023**, *120* (16), e2216948120.

(76) Morawska, L.; Tang, J. W.; Bahnfleth, W.; Bluyssen, P. M.; Boerstra, A.; Buonanno, G.; Cao, J.; Dancer, S.; Floto, A.; Franchimon, F.; Haworth, C.; Hogeling, J.; Isaxon, C.; Jimenez, J. L.; Kurnitski, J.; Li, Y.; Loomans, M.; Marks, G.; Marr, L. C.; Mazzarella, L.; Melikov, A. K.; Miller, S.; Milton, D. K.; Nazaroff, W.;

Nielsen, P. V.; Noakes, C.; Peccia, J.; Querol, X.; Sekhar, C.; Seppänen, O.; Tanabe, S. ichi; Tellier, R.; Tham, K. W.; Wargocki, P.; Wierzbicka, A.; Yao, M. How Can Airborne Transmission of COVID-19 Indoors Be Minimised? *Environ. Int.* **2020**, *142*, 105832.

(77) Zheng, W.; Hu, J.; Wang, Z.; Li, J.; Fu, Z.; Li, H.; Jurasz, J.; Chou, S. K.; Yan, J. COVID-19 Impact on Operation and Energy Consumption of Heating, Ventilation and Air-Conditioning (HVAC) Systems. *Advances in Applied Energy* **2021**, *3*, 100040.

(78) Pistochini, T.; Mande, C.; Chakraborty, S. Modeling Impacts of Ventilation and Filtration Methods on Energy Use and Airborne Disease Transmission in Classrooms. *Journal of Building Engineering* **2022**, *57*, 104840.

(79) Shan, M.; Hwang, B.-g. Green Building Rating Systems: Global Reviews of Practices and Research Efforts. *Sustain Cities Soc.* **2018**, *39*, 172–180.

(80) Brulio-Gonzalo, M.; Jorge-Ortiz, A.; Bovea, M. D. How Are Indicators in Green Building Rating Systems Addressing Sustainability Dimensions and Life Cycle Frameworks in Residential Buildings? *Environ. Impact Assess. Rev.* **2022**, *95*, 106793.

(81) Wei, W.; Ramalho, O.; Mandin, C. Indoor Air Quality Requirements in Green Building Certifications. *Build Environ* **2015**, *92*, 10–19.

(82) Morawska, L.; Allen, J.; Bahnfleth, W.; Bennett, B.; Bluyssen, P. M.; Boerstra, A.; Buonanno, G.; Cao, J.; Dancer, S. J.; Floto, A.; Franchimon, F.; Greenhalgh, T.; Haworth, C.; Hogeling, J.; Isaxon, C.; Jimenez, J. L.; Kennedy, A.; Kumar, P.; Kurnitski, J.; Li, Y.; Loomans, M.; Marks, G.; Marr, L. C.; Mazzarella, L.; Melikov, A. K.; Miller, S. L.; Milton, D. K.; Monty, J.; Nielsen, P. V.; Noakes, C.; Peccia, J.; Prather, K. A.; Querol, X.; Salthammer, T.; Sekhar, C.; Seppänen, O.; Tanabe, S.; Tang, J. W.; Tellier, R.; Tham, K. W.; Wargocki, P.; Wierzbicka, A.; Yao, M. Mandating Indoor Air Quality for Public Buildings. *Science* (1979) **2024**, *383* (6690), 1418–1420.

(83) Net Zero by 2050; IEA: Paris, 2021; <https://www.iea.org/reports/net-zero-by-2050> (accessed 2024-06-11).

(84) Jaysawal, R. K.; Chakraborty, S.; Elangovan, D.; Padmanaban, S. Concept of Net Zero Energy Buildings (NZEB) - A Literature Review. *Clean Eng. Technol.* **2022**, *11*, 100582.

(85) Al Dakheel, J.; Del Pero, C.; Aste, N.; Leonforte, F. Smart Buildings Features and Key Performance Indicators: A Review. *Sustain Cities Soc.* **2020**, *61*, 102328.

(86) Brambilla, A.; Salvalai, G.; Imperadori, M.; Sesana, M. M. Nearly Zero Energy Building Renovation: From Energy Efficiency to Environmental Efficiency, a Pilot Case Study. *Energy Build* **2018**, *166*, 271–283.

(87) D'Agostino, D.; Mazzarella, L. What Is a Nearly Zero Energy Building? Overview, Implementation and Comparison of Definitions. *Journal of Building Engineering* **2019**, *21*, 200–212.

(88) Li, H.; Wang, S. New Challenges for Optimal Design of Nearly/Net Zero Energy Buildings under Post-Occupancy Performance-Based Design Standards and a Risk-Benefit Based Solution Article History. *Build Simul* **2022**, *15*, 685–698.

(89) Shang, W.; Liu, J.; Wang, C.; Li, J.; Dai, X. Developing Smart Air Purifier Control Strategies for Better IAQ and Energy Efficiency Using Reinforcement Learning. *Build Environ* **2023**, *242*, 110556.

(90) An, Y.; Chen, C. Energy-Efficient Control of Indoor PM<sub>2.5</sub> and Thermal Comfort in a Real Room Using Deep Reinforcement Learning. *Energy Build* **2023**, *295*, 113340.

(91) Li, J.; Mattewal, S. K.; Patel, S.; Biswas, P. Evaluation of Nine Low-Cost-Sensor-Based Particulate Matter Monitors. *Aerosol Air Qual Res.* **2020**, *20* (2), 254–270.

(92) Thakur, A. K.; Gingrich, J.; Vance, M. E.; Patel, S. Insights into Low-Cost Pm Sensors Using Size-Resolved Scattering Intensity of Cooking Aerosols in a Test House. *Aerosol Sci. Technol.* **2024**, *58* (7), 739–751.

(93) Ganesh, H. S.; Seo, K.; Fritz, H. E.; Edgar, T. F.; Novoselac, A.; Baldea, M. Indoor Air Quality and Energy Management in Buildings Using Combined Moving Horizon Estimation and Model Predictive Control. *Journal of Building Engineering* **2021**, *33*, 101552.



(94) An, Y.; Xia, T.; You, R.; Lai, D.; Liu, J.; Chen, C. A Reinforcement Learning Approach for Control of Window Behavior to Reduce Indoor PM<sub>2.5</sub> Concentrations in Naturally Ventilated Buildings. *Build Environ* **2021**, *200*, 107978.

(95) Xia, S.; Wei, P.; Liu, Y.; Sonta, A.; Jiang, X. RECA: A Multi-Task Deep Reinforcement Learning-Based Recommender System for Co-Optimizing Energy, Comfort and Air Quality in Commercial Buildings. In *BuildSys 2023 - Proceedings of the 10th ACM International Conference on Systems for Energy-Efficient Buildings, Cities, and Transportation*; Association for Computing Machinery, Inc., 2023; pp 99–109, DOI: [10.1145/3600100.3623735](https://doi.org/10.1145/3600100.3623735).